



Customer: Central States Diesel Generators STK#2783  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 10196  
 Test Date 10-26-20

Engine Make/ Model: John Deere 4045HF285  
 Engine Spec/ Serial: PE4045L229129  
 Unit Make/ Model: Wacker Neuson G100  
 Unit Spec/ Serial: 20149367

Voltage: 277/480 (multi-select)  
 Amperage: 96  
 Kilowatts: 80  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	13586.2	13586.4	13586.7	13586.9	13587.2	13587.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	480	481	480	481
PH2	480	480	480	479	479	480
PH3	479	478	478	479	479	479
Amperage PH1	0	97	96	97	97	0
PH2	0	96	97	97	97	0
PH3	0	97	96	96	97	0
Kilowatts	0	80	80	80	80	0
Oil Pressure	58	54	53	53	52	54
Oil Temperature						
Coolant Temperature	180°F	190°F	190°F	190°F	190°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	33°F	33°F	33°F	34°F	34°F	34°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_