



Customer: Central States Diesel Generators STK#2784
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 10255
 Test Date 11-10-20

Engine Make/ Model: Cummins WSG1068
 Engine Spec/ Serial: 06RS59969
 Unit Make/ Model: Cummins GGHE-5778496
 Unit Spec/ Serial: J060986016 Spec. G

Voltage: 277/480
 Amperage: 72 (test@75%LP)
 Kilowatts: 60
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	257.3	257.5	257.8	258	258.3	258.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	479	479	479	479	480
PH2	480	479	479	479	478	480
PH3	479	479	479	479	479	479
Amperage PH1	0	54	55	55	54	0
PH2	0	55	54	54	55	0
PH3	0	55	55	54	55	0
Kilowatts	0	45	45	45	45	0
Oil Pressure	78	73	72	72	72	74
Oil Temperature						
Coolant Temperature	185°F	200°F	200°F	201°F	200°F	186°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.5	14.5	14.5	14.5	14.5	14.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	61°F	61°F	61°F	60°F	60°F	60°F

Technician Signature: _____

Customer Signature: _____