



Customer: Central States Diesel Generators STK#2795  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 10337  
 Test Date 11-19-20  
 Coolant -55F

Engine Make/ Model: John Deere 6090HF485  
 Engine Spec/ Serial: RG6090L045926  
 Unit Make/ Model: Baldor IDLC275  
 Unit Spec/ Serial: P0907070031

Voltage: 277/480  
 Amperage: 331  
 Kilowatts: 275  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	452	452	452	452	453	453
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	482	482	482	482	482
PH2	484	485	485	484	485	484
PH3	481	482	482	482	482	481
Amperage PH1	0	330	329	330	329	0
PH2	0	329	328	330	329	0
PH3	0	330	329	328	330	0
Kilowatts	0	275	275	275	275	0
Oil Pressure	44	37	35	35	35	37
Oil Temperature						
Coolant Temperature	185°F	191°F	192°F	192°F	192°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.1	27.1	27.1	27.1	27.1	27.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	56°F	56°F	56°F	56°F	55°F	55°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_