



Customer: Central States Diesel Generators STK#2796
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 10350
 Test Date 11-24-20
 Coolant -50F

Engine Make/ Model: John Deere 4045DF150
 Engine Spec/ Serial: PE4045D286047
 Unit Make/ Model: Katolight D40FRJ4
 Unit Spec/ Serial: LM648985-90471-0703

Voltage: 277/480
 Amperage: 48
 Kilowatts: 40
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	56	56	57	57	57	57
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	479	480	480	480
PH2	480	479	480	480	479	480
PH3	480	480	480	479	480	480
Amperage PH1	0	48	48	48	48	0
PH2	0	48	48	48	48	0
PH3	0	47	48	48	48	0
Kilowatts	0	40	40	40	40	0
Oil Pressure	65	57	53	53	53	55
Oil Temperature						
Coolant Temperature	170°F	176°F	177°F	177°F	177°F	172°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	35°F	35°F	35°F	35°F	35°F	35°F

Technician Signature: _____

Customer Signature: _____