

GENERAC

Customer: CSDG
 Address: _____
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 10514
 Test Date 1/13/2021

Engine Make/ Model: Caterpillar C18
 Engine Spec/ Serial: FST01034 / 272-6915
 Unit Make/ Model: Caterpillar LC7
 Unit Spec/ Serial: G7A03115 / 247-6127

Voltage: 480V
 Amperage: 902A
 Kilowatts: 600KW
 Power Factor 0.8PF

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	401		401		402							402
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	35	245	521	719	719							0
PH2	35	245	521	719	719							0
PH3	34	245	521	719	719							0
Kilowatts	29	203	433	597	597	0	0	0	0	0	0	0
Oil Pressure	108	97	92	85	83							83
Oil Temperature												
Coolant Temperature	141°F	163°F	176°F	182°F	185°F							165°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	27	27	27	27	27							27
Natural Gas Pressure												
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	30°F	30°F	30°F	30°F	30°F							30°F

Cable Length: 25'Cable/ Leg: 2Connection Point: BreakerTechnician Signature: JOHN COVILL

Customer Signature: _____