

GENERAC

Customer: CSDG _____
 Address: _____
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 10401
 Test Date 12/4/2020

Engine Make/ Model: Cummins KTA50-G3 _____
 Engine Spec/ Serial: 25268160, CPL 2227 _____
 Unit Make/ Model: Onan DFLLC-4955290 _____
 Unit Spec/ Serial: C010218484, Spec. T _____

Voltage: 480V _____
 Amperage: 1879A _____
 Kilowatts: 1250KW _____
 Power Factor 0.8PF _____

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	441				442							442
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	312	791	1423	1423	1422							0
PH2	314	789	1421	1421	1420							0
PH3	313	787	1417	1417	1415							0
Kilowatts	260	655	1179	1179	1178	0	0	0	0	0	0	0
Oil Pressure	115	110	96	89	86							89
Oil Temperature												
Coolant Temperature	132°F	169°F	173°F	174°F	174°F							168°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	27	27	27	27	27							27
Natural Gas Pressure												
Diesel Fuel Level	35	35	30	30	25							25
Room Temperature												
Ambient Temperature	38°F	38°F	41°F	43°F	43°F							43°F

Cable Length: 50 _____

Cable/ Leg: 4 _____

Connection Point: Output breaker _____

Technician Signature: John Colini

Customer Signature: _____