

GENERAC

Customer: CSDG
 Address: _____
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 10988
 Test Date 5/14/2021

Engine Make/ Model: John Deere 6081TF001
 Engine Spec/ Serial: RG6081T154418
 Unit Make/ Model: Katolight D150FPJ4
 Unit Spec/ Serial: 82649-0702

Voltage: 480VAC
 Amperage: 225A
 Kilowatts: 150KW
 Power Factor 0.8PF

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	370				371							371
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	55	126	180	180	180							0
PH2	56	128	181	180	181							0
PH3	58	128	181	181	181							0
Kilowatts	47	106	150	150	150	0	0	0	0	0	0	0
Oil Pressure	55	50	45	40	40							40
Oil Temperature												
Coolant Temperature	125°F	155°F	170°F	175°F	175°F							170°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	14	14	14	14	14							14
Natural Gas Pressure												
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	65°F	65°F	70°F	70°F	70°F							70°F

Cable Length: 25Cable/ Leg: 1Connection Point: Output BreakerTechnician Signature: John Colini

Customer Signature: _____