



Customer: Central States Diesel Generators STK#2808  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 10426  
 Test Date 12-17-20

Engine Make/ Model: Generac Power Systems SC13GT304D (Natural Gas)  
 Engine Spec/ Serial: G913C005842  
 Unit Make/ Model: Generac MG0200KG20129N18GPYYE  
 Unit Spec/ Serial: 8721999

Voltage: 277/480  
 Amperage: 241  
 Kilowatts: 200 Test@75 L.P.  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	136	136.2	136.5	136.7	137	137.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	481	481	481	480
PH2	480	481	481	480	480	480
PH3	482	481	482	481	481	482
Amperage PH1	0	90	90	91	90	0
PH2	0	90	91	91	90	0
PH3	0	90	91	90	90	0
Kilowatts	0	75	75	75	75	0
Oil Pressure	98	92	90	90	90	92
Oil Temperature						
Coolant Temperature	170°F	170°F	170°F	170°F	170°F	172°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.3	28.3	28.3	28.3	28.3	28.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	27°F	27°F	27°F	26°F	26°F	26°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_