



Customer: Central States Diesel Generators STK#2809  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 10427  
 Test Date 12-17-20

Engine Make/ Model: Generac Power Systems SC13GT304D  
 Engine Spec/ Serial: G913C005838  
 Unit Make/ Model: Generac MG0200KG20129N18GPYYE  
 Unit Spec/ Serial: 8721998

Voltage: 277/480  
 Amperage: 241  
 Kilowatts: 200 Test@75 L.P.  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	123.8	124	124.3	124.5	124.8	124.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	481	481	481	480
PH2	480	481	481	480	480	480
PH3	481	481	480	481	481	479
Amperage PH1	0	90	91	91	90	0
PH2	0	91	91	90	90	0
PH3	0	90	90	91	90	0
Kilowatts	0	75	75	75	75	0
Oil Pressure	105	98	97	97	96	98
Oil Temperature						
Coolant Temperature	170°F	175°F	175°F	175°F	175°F	172°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.3	28.3	28.3	28.3	28.3	28.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	28°F	28°F	28°F	28°F	28°F	28°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_