

GENERAC

Customer: Central States Diesel Generators STK#2311
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 10929
 Test Date 5/17/2021

Engine Make/ Model: Ford LSG-8751-6005-A
 Engine Spec/ Serial: 225664
 Unit Make/ Model: Cummins Onana 100ENBA
 Unit Spec/ Serial: B950568394

Voltage: 208
 Amperage: _____
 Kilowatts: 100
 Power Factor: _____

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	140.5				141.5							
Hertz/Cycles	60	60	60	60	60							
Voltage PH1	480	480	480	480	480							
PH2	480	480	480	480	480							
PH3	480	480	480	480	480							
Amperage PH1	60	90	110	120	120							
PH2	60	90	110	120	120							
PH3	60	90	110	120	120							
Kilowatts	50	75	91	100	100	0	0	0	0	0	0	0
Oil Pressure	50	50	50	50	50							
Oil Temperature												
Coolant Temperature	170°F	170°F	176°F	176°F	176°F							
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	13.74	13.74	13.74	13.74	13.74							
Natural Gas Pressure												
Diesel Fuel Level	na											
Room Temperature												
Ambient Temperature	68°F	68°F	68°F	68°F	68°F							

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Matt Czaplinski

Customer Signature: _____