

## Great Lakes Industrial Diesel

2-23-21

CSDG: 2819

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: Coolant good to -25 deg F
- Yes  No  NA Visual inspection of radiator: No visible issues or performance issues
- Yes  No  NA Visual inspection of radiator hoses: No visible issues
- Yes  No  NA Check condition of coolant hoses: No visible issues
- Yes  No  NA Check condition of fuel hoses: No visible issues
- Yes  No  NA Check condition of engine belts: Good working condition
- Yes  No  NA Batteries and QTY: 2 Group 31 core batteries
- Yes  No  NA Battery install date if applicable: No install date marked
- Yes  No  NA Genset has battery charger: Installed behind control panel
- Yes  No  NA Genset has coolant heater: Coolant heater is on genset
- Yes  No  NA Check engine oil level: Oil level full
- Yes  No  NA Engine oil filters last changed date and HRS: No hours or dates
- Yes  No  NA Inspect exhaust system for cracks / leaks: No issues with exhaust system
- Yes  No  NA Check rain cap for proper operation: Rain cap working as designed
- Yes  No  NA Generator end is 12 lead reconnectable: 6 lead 4 pole generator 480VAC
- Yes  No  NA Generator end has PMG permanent magnet generator: Generator has no PMG