



Customer: Central States Diesel Generators STK#2820  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 10441  
 Test Date 12-17-20

Engine Make/ Model: Ford WSG1068  
 Engine Spec/ Serial: 05YS40078  
 Unit Make/ Model: Generac 5344500100  
 Unit Spec/ Serial: 2083691

Voltage: 120/240 1PH  
 Amperage: 417  
 Kilowatts: 100 (test 75KW LP)  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	0	0.2	0.5	0.7	0.9	1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	240	240	240	240	240	240
PH1 to N	120	120	120	120	120	120
PH2 to N	120	120	120	120	120	120
Amperage PH1	0	311	312	312	311	0
PH2	0	312	311	310	311	0
PH3	0	310	312	311	311	0
Kilowatts	0	75	75	75	75	0
Oil Pressure	60	58	57	57	57	58
Oil Temperature						
Coolant Temperature	185°F	192°F	192°F	193°F	193°F	186°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.5	13.5	13.5..	13.5	13.5	13.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	25°F	25°F	25°F	25°F	24°F	24°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_