



## Great Lakes Industrial Diesel

2-10-21

CSDG: 2821

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: New coolant good to -34 deg F
  - Yes  No  NA Visual inspection of radiator: No visible issues or performance issues
  - Yes  No  NA Visual inspection of radiator hoses: No visible issues
  - Yes  No  NA Check condition of coolant hoses: No visible issues
  - Yes  No  NA Check condition of fuel hoses: No visible issues
  - Yes  No  NA Check condition of engine belts: Good working condition
  - Yes  No  NA Batteries and QTY:
  - Yes  No  NA Battery install date if applicable: No install date marked
  - Yes  No  NA Genset has battery charger:
  - Yes  No  NA Genset has coolant heater: Coolant heater is on genset
  - Yes  No  NA Check engine oil level: Oil level full
  - Yes  No  NA Engine oil filters last changed date and HRS: Fresh oil change and fuel filter change
- 2-10-21**
- Yes  No  NA Inspect exhaust system for cracks / leaks: No issues with exhaust system
  - Yes  No  NA Check rain cap for proper operation: No rain cap
  - Yes  No  NA Generator end is 12 lead reconnectable: Unit is connected to 480 VAC
  - Yes  No  NA Generator end has PMG permanent magnet generator: Generator has a PMG