

GENERAC

Customer: CSDG
 Address: _____
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 10655
 Test Date 2/26/2021

Engine Make/ Model: Cummins KTA50-GSI
 Engine Spec/ Serial: 33115114
 Unit Make/ Model: Cummins 1000KTA51/33781D
 Unit Spec/ Serial: B892176825

Voltage: 480VAC
 Amperage: 1504A
 Kilowatts: 1000KW
 Power Factor 0.8PF

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	1298	1298	1298	1299	1299							1299
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	234	675	1156	1156	1156							0
PH2	236	674	1155	1156	1154							0
PH3	235	672	1155	1155	1155							0
Kilowatts	195	559	959	960	959	0	0	0	0	0	0	0
Oil Pressure	115	112	105	101	101							100
Oil Temperature	72°F	105°F	145°F	162°F	174°F							175°F
Coolant Temperature	135°F	156°F	168°F	172°F	174°F							171°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	27	27	27	27	27							27
Natural Gas Pressure												
Diesel Fuel Level	50	50	50	50	50							50
Room Temperature												
Ambient Temperature	28°F	32°F	41°F	41°F	41°F							42°F

Cable Length: 25Cable/ Leg: 3Connection Point: buss barTechnician Signature: John Colini

Customer Signature: _____