

**GENERAC**

Customer: CSDG  
 Address: \_\_\_\_\_  
 City/ State/ Zip \_\_\_\_\_  
 Contact: \_\_\_\_\_  
 Phone: \_\_\_\_\_

R#: 10656  
 Test Date 2/25/2021

Engine Make/ Model: Cummins KTA50-GS1  
 Engine Spec/ Serial: 33115113  
 Unit Make/ Model: Cummins 1000KTA51/33781D  
 Unit Spec/ Serial: K882176825

Voltage: 480VAC  
 Amperage: 1504A  
 Kilowatts: 1000KW  
 Power Factor 0.8PF

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	1283	1283	1284	1284	1284							1284
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	244	662	1153	1153	1152							0
PH2	243	661	1153	1152	1152							0
PH3	242	663	1153	1152	1151							0
Kilowatts	202	550	957	957	956	0	0	0	0	0	0	0
Oil Pressure	112	105	102	98	96							96
Oil Temperature	73°F	110°F	156°F	165°F	168°F							170°F
Coolant Temperature	124°F	156°F	171°F	172°F	172°F							168°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	27	27	27	27	27							27
Natural Gas Pressure												
Diesel Fuel Level	50	50	50	50	50							50
Room Temperature												
Ambient Temperature	46°F	46°F	44°F	43°F	42°F							42°F

Cable Length: 25Cable/ Leg: 3Connection Point: buss barTechnician Signature: John Colini

Customer Signature: \_\_\_\_\_