

**GENERAC**

aksa POWER GENERATION



Customer: CSDG  
 Address: \_\_\_\_\_  
 City/ State/ Zip \_\_\_\_\_  
 Contact: \_\_\_\_\_  
 Phone: \_\_\_\_\_

R#: 10776  
 Test Date 2021-03-25

Engine Make/ Model: Cummins QSK23G7 NR2  
 Engine Spec/ Serial: 326066  
 Unit Make/ Model: Onan DQCB-1327643  
 Unit Spec/ Serial: F130521019 spec H

Voltage: 480V  
 Amperage: 1127A  
 Kilowatts: 750KW  
 Power Factor: 0.8PF

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	127	127	127	127	128	128
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	369	545	905	904	904	0
PH2	365	545	904	904	903	0
PH3	367	544	903	903	902	0
Kilowatts	305	452	751	750	750	0
Oil Pressure	119	95	87	84	81	83
Oil Temperature						
Coolant Temperature	109°F	146°F	156°F	165°F	172°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	43°F	43°F	43°F	42°F	42°F	42°F

Cable Length: 15 \_\_\_\_\_

Cable/ Leg: 2 \_\_\_\_\_

Connection Point: Output Breaker \_\_\_\_\_

Technician Signature: John Colini \_\_\_\_\_

Customer Signature: \_\_\_\_\_