

GENERAC

Customer: Central States Diesel Generators Unit #2838
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: _____

R#: 11604
 Test Date 11/8/2021

Engine Make/ Model: Cummins KTA19G
 Engine Spec/ Serial: 37258497
 Unit Make/ Model: Onan 350GFEB
 Unit Spec/ Serial: M131371710

Voltage: 480VAC
 Amperage: 526A
 Kilowatts: 350KW
 Power Factor 0.8PF

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	290	290	290	290	291							291
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	136	242	421	421	421							0
PH2	136	242	421	421	421							0
PH3	136	242	421	421	421							0
Kilowatts	113	201	350	350	350	0	0	0	0	0	0	0
Oil Pressure	98	94	91	91	91							94
Oil Temperature												
Coolant Temperature	174°F	183°F	183°F	184°F	184°F							174°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	27	27	27	27	27							27
Natural Gas Pressure	17	17	17	17	17							17
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	68°F	68°F	68°F	68°F	68°F							68°F

Cable Length: 25 _____

Cable/ Leg: 1 _____

Connection Point: Breaker _____

Technician Signature: John Colini

Customer Signature: _____