

Cummins GFEB SN-M131371710 as shipped
ENGINE MODEL : KTA19SLB
S/N 37258497
ENGINE PO# : 80667321
COMPRESSION RATIO : 8.5:1
GENERATOR MODEL : HC504C
S/N M131371710
GENERATOR PO# : 80668115
KW : 350
STANDBY :
VOLTS : 277/480
KVA : 438
60 HZ :
FLA : 526
PHASE : 3
PF : 0.8
RADIATOR
STD SUB-BASE WITH INTREGAL ISOLATORS
STD AIR CLEANER
GOVERNOR : STD. ELECTRIC
CT KIT # 300-4623-29
CT- 1262
ENGINE INSTRUMENT PANEL: PCC 2300
LEFT SIDE
--OIL PRESSURE GAUGE (INCLUDED ON PANEL)
--OIL TEMP
--WATER TEMP GAUGE
--HOUR METER
--BATTERY VOLTMETER
GENERATOR PANEL
--AMMETER
--VOLTMETER
--FREQUENCY METER
--AM/VM SELECTOR SWITCH
SAFETY SHUTDOWNS
--HIGH WATER TEMP STD
--LOW OIL PRESSURE STD
--OVERSPEED
--LOW COOLANT LEVEL: STD
PRE ALARMS
--HIGH WATER TEMP
--LOW OIL PRESSURE
--LOW COOLANT TEMP
OVERCRANK
MAIN LINE CIRCUIT BREAKER : 600AMP LEFT
STRIP HEATERS : IN GEN

COOLANT HEATER: 4000W 240/480V
YES, INSTALL OIL & COOLANT DRAIN EXTENSIONS
OIL :
ANTIFREEZE :
CRITICAL SILENCER: LOOSE
FLEX EXHAUST CONNECTION: LOOSE
BATTERY RACK:
BATTERY CABLES : (INSTALL AFTER THE UNIT IS PAINTED) BATTERY
CHARGER : 300-5878-01 (INSTALL & WIRE) INSTALL K631 RELAYS
INSTALL AN ALARM HORN
VIBRO MOUNTS : INTERGAL
ONAN GREEN PAINT :
MANUALS: 900-0665
SHIPPING SKID : 17168
FLEX FUEL LINES: MM-2-15 LOOSE
STRAINER; 149-0751 LOOSE
E-STOP SWITCH STD
PLACE WITNESS MARK ON TORQUE BOLTS
EXTENDED 4 HOUR LOAD TEST
TEST RECORD STRIP CHART & GRAPHING
TEST RECORD SAFETY SHUTDOWNS
TEST RECORD EXHAUST TEMP/AMBIENT TEMP & PRESSURE
CERTIFIED TEST REPORT
INSTALL ECM RESET STICKER # 17282 ON CONTROL PANEL
***MUST TEST UNIT WITH FACTORY AFR INSTALLED AND DOCUMENT USING
TESTO 350 EMISSION ANALYZER***
5 YEAR WARRANTY
=====

SQ NO. 159329