

Great Lakes Industrial Diesel

2-24-21

CSDG: 2838

Generator Check list

Inspection Description

- ☒ Yes ☐ No ☐ NA Check coolant level and record freeze protection: Coolant good to -25 deg F on both aftercooler side and radiator side
- ☒ Yes ☐ No ☐ NA Visual inspection of radiator: No visible issues
- ☒ Yes ☐ No ☐ NA Visual inspection of radiator hoses: No visible issues
- ☒ Yes ☐ No ☐ NA Check condition of coolant hoses: No visible issues
- ☒ Yes ☐ No ☐ NA Check condition of fuel hoses: No visible issues
- ☒ Yes ☐ No ☐ NA Check condition of engine belts: No visible issues
- ☒ Yes ☐ No ☐ NA Batteries and QTY: 2 8D batteries
- ☒ Yes ☐ No ☐ NA Battery install date if applicable: Installed July 25th, 2017
- ☒ Yes ☐ No ☐ NA Genset has battery charger: Mounted on gen doghouse
- ☒ Yes ☐ No ☐ NA Genset has coolant heater: Coolant heater is on genset
- ☒ Yes ☐ No ☐ NA Check engine oil level: Oil level full
- ☐ Yes ☐ No ☒ NA Engine oil filters last changed date and HRS: Unknown
- ☒ Yes ☐ No ☐ NA Inspect exhaust system for cracks / leaks: No visible issues
- ☐ Yes ☐ No ☒ NA Check rain cap for proper operation: No rain cap steel plate covering exhaust
- ☒ Yes ☐ No ☐ NA Generator end is 12 lead reconnectable: Generator is 12 lead
- ☒ Yes ☐ No ☐ NA Generator end has PMG permanent magnet generator: Unit has a PMG