



Customer: Central States Diesel Generators
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 11061
 Test Date 2021.04.26

Engine Make/ Model: MTU 8V2000
 Engine Spec/ Serial: 5312001536, Spec A 361564
 Unit Make/ Model: Kohler 500ROZD4
 Unit Spec/ Serial: 0712696, GM16975-GA1

Voltage: 480
 Amperage: 759
 Kilowatts: 505
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	909	909	909	910	910	910
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	256	459	605	605	605	0
PH2	256	458	606	605	605	0
PH3	257	459	606	606	606	0
Kilowatts	213	381	503	503	503	0
Oil Pressure	100	71	62	62	62	68
Oil Temperature						
Coolant Temperature	145°F	172°F	176°F	176°F	177°F	169°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	65°F	65°F	65°F	65°F	65°F	65°F

Technician Signature: John Colini

Customer Signature: _____