



Customer: Central States Diesel Generators STK#2880
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 11064
 Test Date 6-9-21

Engine Make/ Model: John Deere 6068TF275
 Engine Spec/ Serial: PE6068T597826
 Unit Make/ Model: Wacker G125
 Unit Spec/ Serial: 5677475

Voltage: 120/208 Multi
 Amperage: 216
 Kilowatts: 109
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	11408	11408.2	11408.5	11408.7	11409	11409.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	216	215	215	216	216	216
PH1 to N	215	215	215	216	215	215
PH2 to N	216	216	216	215	216	216h
Amperage PH1	290	290	289	289	290	0
PH2	289	289	290	290	289	0
PH3	290	289	289	290	291	0
Kilowatts	109	108	109	109	109	0
Oil Pressure	58	53	51	51	51	52
Oil Temperature						
Coolant Temperature	180°F	185°F	186°F	186°F	186°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.4	14.4	14.4	14.4	14.4	14.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	75°F	75°F	75°F	76°F	76°F	77°F

Technician Signature: Randy Pool

Customer Signature: _____

Charles Equipment

6-9-21

CSDG # 2880

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: **Level Good -40F**
- Yes No NA Visual inspection of radiator: **No visible issues or performance issues**
- Yes No NA Visual inspection of radiator hoses: **No visible issues**
- Yes No NA Check condition of coolant hoses: **Okay**
- Yes No NA Check condition of fuel hoses: **No visible issues**
- Yes No NA Check condition of engine belts: **Good Condition**
- Yes No NA Batteries and QTY: **Quantity (1) Group 31D**
- Yes No NA Battery install date if applicable: **Not Marked**
- Yes No NA Genset has battery charger: **120VAC input 12VDC 5A output**
- Yes No NA Genset has coolant heater: **120Vac/ 1500W**
- Yes No NA Check engine oil level: **Oil level is full/Appearance Okay**
- Yes No NA Engine oil filters last changed date and HRS: **3/29/21 11,408 Hrs.**
- Yes No NA Inspect exhaust system for cracks / leaks: **Okay**
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable: **Yes**
- Yes No NA Generator end has PMG permanent magnet generator: **YES**