



## Great Lakes Industrial Diesel

4-7-21

CSDG: 2882

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: **Full good to -10 deg. F.**
- Yes  No  NA Visual inspection of radiator: **No visible issues or performance issues**
- Yes  No  NA Visual inspection of radiator hoses: **No visible issues**
- Yes  No  NA Check condition of coolant hoses: **No visible issues**
- Yes  No  NA Check condition of fuel hoses: **No visible issues**
- Yes  No  NA Check condition of engine belts: **Good working condition**
- Yes  No  NA Batteries and QTY: **2 Group 31 batteries in good condition**
- Yes  No  NA Battery install date if applicable:
- Yes  No  NA Genset has battery charger: **Battery charger mounted by gen end**
- Yes  No  NA Genset has coolant heater: **120VAC coolant heater in engine freeze plug**
- Yes  No  NA Check engine oil level: **Oil level full**
- Yes  No  NA Engine oil filters last changed date and HRS: **9273 HRS 4-6-21**
- Yes  No  NA Inspect exhaust system for cracks / leaks: **No issues with exhaust system**
- Yes  No  NA Check rain cap for proper operation: **No issues**
- Yes  No  NA Generator end is 12 lead reconnectable: **12 lead with change over board**
- Yes  No  NA Generator end has PMG permanent magnet generator: **No PMG**