

Great Lakes Industrial Diesel

3-15-21

CSDG: 2883

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: Full good to -34 deg. F.
- Yes No NA Visual inspection of radiator: No visible issues or performance issues
- Yes No NA Visual inspection of radiator hoses: No visible issues
- Yes No NA Check condition of coolant hoses: No visible issues
- Yes No NA Check condition of fuel hoses: No visible issues
- Yes No NA Check condition of engine belts: Good working condition
- Yes No NA Batteries and QTY:
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: 120/240 VAC coolant heater
- Yes No NA Check engine oil level: Oil level full
- Yes No NA Engine oil filters last changed date and HRS:
- Yes No NA Inspect exhaust system for cracks / leaks: No issues with exhaust system
- Yes No NA Check rain cap for proper operation: No issues covered with steel plate
- Yes No NA Generator end is 12 lead reconnectable: 12 lead wired 277/480
- Yes No NA Generator end has PMG permanent magnet generator: Unit has a PMG