

GENERAC



Customer: central states diesel generators
 Address: _____
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 10829
 Test Date 2021-03-19

Engine Make/ Model: Detroit/ 6063-tkg5
 Engine Spec/ Serial: 06r0820805
 Unit Make/ Model: kohler 230rzdb
 Unit Spec/ Serial: 2031152

Voltage: 480
 Amperage: _____
 Kilowatts: 230
 Power Factor _____

	5 Min.	15 Min.	30 Min.	Cool Down
Eng Hours	368		368	
Hertz/Cycles	60	60	60	
Voltage PH1	482	482	482	
PH2	482	482	482	
PH3	482	482	482	
Amperage PH1	273	273	273	
PH2	273	273	273	
PH3	273	273	273	
Kilowatts	228	228	228	0
Oil Pressure	50	50	50	
Oil Temperature				
Coolant Temperature	185°F	185°F	185°F	
Man Vac./Press. L/B				
Man Vac./Press. R/B				
L/B Exhaust Temp				
R/B Exhaust Temp				
Exhaust Temperature				
DC Voltage	28	28	28	
Natural Gas Pressure				
Diesel Fuel Level	na			
Room Temperature				
Ambient Temperature	57°F	57°F	57°F	

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: matt

Customer Signature: _____