

GENERAC

aksa POWER GENERATION



Customer: CEES
 Address: 530 Santa Rosa dr
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 11069
 Test Date 7/7/21

Engine Make/ Model: GM 8.1
 Engine Spec/ Serial: 8P1L0751
 Unit Make/ Model: KOHLER
 Unit Spec/ Serial: 2051343

Voltage: 480
 Amperage: 150
 Kilowatts: 125
 Power Factor: 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	423	180.3	180.6	180.8	424	181.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	
PH2	480	480	480	480	480	
PH3	480	480	480	480	480	
Amperage PH1	53	57	146	146	146	0
PH2	54	57	146	146	146	0
PH3	53	58	146	146	146	0
Kilowatts	44	48	121	121	121	0
Oil Pressure	75	60	55	52	52	64
Oil Temperature						
Coolant Temperature	120°F	1180°F	202°F	202°F	202°F	195°F
ATION ENGINE FRONT						
RATION ENGINE REAR						
SOUND@75FT						
Exhaust Temperature						
DC Voltage	14.4	14.6	14.5	14.5	14.5	14.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	60°F	60°F	60°F	60°F	60°F	60°F

Cable Length: 20

Cable/ Leg: 1

Connection Point: BREAKERS

Technician Signature: JEFF edwards

Customer Signature: _____