

Great Lakes Industrial Diesel

4-19-21

CSDG: 2922

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: Full good to -25 deg. F.
- Yes No NA Visual inspection of radiator: No visible issues or performance issues
- Yes No NA Visual inspection of radiator hoses: No visible issues
- Yes No NA Check condition of coolant hoses: No visible issues
- Yes No NA Check condition of fuel hoses: No visible issues
- Yes No NA Check condition of engine belts: Good working condition
- Yes No NA Batteries and QTY:
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger: Battery charger mounted by gen end
- Yes No NA Genset has coolant heater: 120VAC coolant heater in engine freeze plug
- Yes No NA Check engine oil level: Oil level full
- Yes No NA Engine oil filters last changed date and HRS: Unable to read writing on filters clearly
- Yes No NA Inspect exhaust system for cracks / leaks: No issues with exhaust system
- Yes No NA Check rain cap for proper operation: No issues
- Yes No NA Generator end is 12 lead reconnectable: 12 lead
- Yes No NA Generator end has PMG permanent magnet generator: No PMG