

GENERAC

Customer: CSDG
 Address: _____
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 11146
 Test Date 6/17/2021

Engine Make/ Model: Caterpillar 3508STD
 Engine Spec/ Serial: 4GM00312, 128-2845
 Unit Make/ Model: Caterpillar
 Unit Spec/ Serial: _____

Voltage: 480V
 Amperage: 1504A
 Kilowatts: 1000KW
 Power Factor 0.8PF

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	557	558	558	558	558							559
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	342	760	1202	1202	1202							0
PH2	342	760	1202	1202	1202							0
PH3	342	760	1202	1202	1202							0
Kilowatts	284	631	998	998	998	0	0	0	0	0	0	0
Oil Pressure	78	68	66	64	62							65
Oil Temperature												
Coolant Temperature	172°F	178°F	185°F	190°F	194°F							178°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	28	28	28	28	28							28
Natural Gas Pressure												
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	82°F	82°F	82°F	82°F	82°F							82°F

Cable Length: 25Cable/ Leg: 3Connection Point: Output breakerTechnician Signature: JOHN COVILL

Customer Signature: _____