

GENERAC

Customer: CSDG
 Address: _____
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 11148
 Test Date 5/14/2021

Engine Make/ Model: Caterpillar 3508B
 Engine Spec/ Serial: 4GM00493, 128-2845
 Unit Make/ Model: Caterpillar SR4B
 Unit Spec/ Serial: 2GM00865, 144-1692

Voltage: 480V
 Amperage: 1504A
 Kilowatts: 1000KW
 Power Factor 0.8PF

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	463	463	463	463	464							464
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	345	710	1202	1202	1201							0
PH2	342	712	1201	1202	1202							0
PH3	345	712	1201	1201	1203							0
Kilowatts	286	591	998	998	998	0	0	0	0	0	0	0
Oil Pressure	85	79	78	73	71							73
Oil Temperature												
Coolant Temperature	135°F	156°F	178°F	184°F	184°F							168°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	27	27	27	27	27							27
Natural Gas Pressure												
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	70°F	70°F	70°F	70°F	70°F							70°F

Cable Length: 25Cable/ Leg: 3Connection Point: Output BreakerTechnician Signature: John Colini

Customer Signature: _____