



Customer: Central States Diesel Generators STK#2950  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 11143  
 Test Date 5-6-21

Engine Make/ Model: John Deere 6059TF002  
 Engine Spec/ Serial: CD6059T415976  
 Unit Make/ Model: Kohler 80R0ZJ  
 Unit Spec/ Serial: PA-189550 0708854

Voltage: 120/208  
 Amperage: 261  
 Kilowatts: 94  
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	774	774.2	774.5	774.7	775	775.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	210	210	209	209	210	210
PH1 to N	209	209	210	209	209	209
PH2 to N	210	210	210	211	210	210
Amperage PH1	0	260	258	259	259	0
PH2	0	259	260	258	260	0
PH3	0	260	258	259	260	0
Kilowatts	0	94	94	94	94	0
Oil Pressure	45	42	40	40	40	42
Oil Temperature						
Coolant Temperature	180°F	192°F	193°F	193°F	193°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	47°F	47°F	47°F	48°F	48°F	48°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

## Charles Equipment

5-6-21

CSDG # 2950

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: **Level Good -40F**
- Yes  No  NA Visual inspection of radiator: **No visible issues or performance issues**
- Yes  No  NA Visual inspection of radiator hoses: **No visible issues**
- Yes  No  NA Check condition of coolant hoses: **No visible issues**
- Yes  No  NA Check condition of fuel hoses: **No visible issues**
- Yes  No  NA Check condition of engine belts: **Good Condition**
- Yes  No  NA Batteries and QTY: **Quantity (1) Group 31**
- Yes  No  NA Battery install date if applicable: **11/2000**
- Yes  No  NA Genset has battery charger: **No**
- Yes  No  NA Genset has coolant heater: **120VAC/1500WATT**
- Yes  No  NA Check engine oil level: **Oil level is full/Appearance fair**
- Yes  No  NA Engine oil filters last changed date and HRS: **Not Dated**
- Yes  No  NA Inspect exhaust system for cracks / leaks: **No issues with exhaust system**
- Yes  No  NA Check rain cap for proper operation: **Okay**
- Yes  No  NA Generator end is 12 lead reconnectable: **OK**
- Yes  No  NA Generator end has PMG permanent magnet generator: **No**