



Customer: Central States Diesel Generators
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 11073
 Test Date 2021.04.26

Engine Make/ Model: Cummins 6BT5.9-G6
 Engine Spec/ Serial: 46063076
 Unit Make/ Model: Onan DGDA-4954438
 Unit Spec/ Serial: A010198732

Voltage: 208
 Amperage: 277
 Kilowatts: 80
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	249	249	249	249	250	250
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	208	208	208	208	208	208
PH3	208	208	208	208	208	208
Amperage PH1	85	146	211	211	211	
PH2	84	146	212	211	212	
PH3	84	146	212	211	212	
Kilowatts	30	53	76	76	76	0
Oil Pressure	85	65	63	61	61	65
Oil Temperature						
Coolant Temperature	170°F	185°F	185°F	186°F	186°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	71°F	71°F	71°F	71°F	71°F	71°F

Technician Signature: _____

Customer Signature: _____