

<b>Customer:</b>		<b>kW Rating:</b>	1750	<b>Date:</b>	5/28/2021
<b>Address:</b>	5123 Hiltonview Rd. Houston, TX 77086	<b>Model:</b>	DQKB-4490509	<b>Technician:</b>	Victor P
<b>Contact:</b>		<b>Serial Number:</b>	A010193066	<b>Job/Item #:</b>	2416

Time	Load %	kW	Amps			Volts			Hz	Oil Pressure	Water Temp.	Ambient Temp.
			A	B	C	A-B	A-C	B-C				
4:20 PM	0	0	0	0	0	480	480	480	60	72	151	85
4:35 PM	53	930	1103	1101	1102	480	480	480	60	67	174	85
4:50 PM	74	1300	1544	1516	1550	480	480	480	60	64	179	85
5:05 PM	98	1722	2041	2016	2050	480	480	480	60	62	184	85
5:20 PM	97	1710	2025	1998	2034	480	480	480	60	61	185	

**COMMENTS: 15 Minutes @ 50% Load; 15 Minutes @ 75% Load; 30 Minutes @ 100% Load**  
 If load requirements are not achievable due to load bank steps, load unit as close to the load requirement as possible. Record in notes section below.