

**GENERAC**

aksa POWER GENERATION



Customer: Central States Diesel Generators STK#2961  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 11228  
 Test Date 6/1/21

Engine Make/ Model: FORD WSG1068  
 Engine Spec/ Serial: E182A-130906-2566327  
 Unit Make/ Model: CUMMINS GGHH -5779135  
 Unit Spec/ Serial: K060989795

Voltage: 480  
 Amperage: 120  
 Kilowatts: 100  
 Power Factor: 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	180.1	180.3	180.6	180.8	181.1	181.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	
PH2	480	480	480	480	480	
PH3	480	480	480	480	480	
Amperage PH1	53	57	118	118	118	0
PH2	54	57	118	118	118	0
PH3	53	58	119	119	119	0
Kilowatts	44	48	98	98	98	0
Oil Pressure	75	60	55	52	52	64
Oil Temperature						
Coolant Temperature	187°F	198°F	202°F	202°F	202°F	195°F
ATION ENGINE FRONT						
RATION ENGINE REAR						
SOUND@75FT						
Exhaust Temperature						
DC Voltage	14.4	14.6	14.5	14.5	14.5	14.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	60°F	60°F	60°F	60°F	60°F	60°F

Cable Length: 20

Cable/ Leg: 1

Connection Point: BREAKERS

Technician Signature: Jeff Edwards

Customer Signature: