

GENERAC

Customer: CSDG
 Address: _____
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 11293
 Test Date 6/17/2021

Engine Make/ Model: Cummins KTA19-G3
 Engine Spec/ Serial: 37141656
 Unit Make/ Model: Onan 450DFEC
 Unit Spec/ Serial: C920454053, 54396A

Voltage: 480V
 Amperage: 677A
 Kilowatts: 450KW
 Power Factor 0.8PF

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	1519	1519	1519	1519	1520							1520
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	145	360	541	541	541							0
PH2	145	360	541	541	541							0
PH3	145	360	541	541	541							0
Kilowatts	120	299	449	449	449	0	0	0	0	0	0	0
Oil Pressure	100	100	98	98	98							98
Oil Temperature												
Coolant Temperature	170°F	185°F	187°F	187°F	187°F							175°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	28	28	28	28	28							28
Natural Gas Pressure												
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	82°F	82°F	82°F	82°F	82°F							82°F

Cable Length: 25Cable/ Leg: 2Connection Point: Output breakerTechnician Signature: JOHN COVILL

Customer Signature: _____