



Customer: Central States Diesel Generators STK#2991  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 11258  
 Test Date 7-23-21

Engine Make/ Model: Cummins QSL9-G3 NR3  
 Engine Spec/ Serial: 73457258  
 Unit Make/ Model: Cummins DQDAA-1213473  
 Unit Spec/ Serial: F J120403892

Voltage: 277/480  
 Amperage: 301  
 Kilowatts: 250  
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	425	425.2	425.5	425.7	426	426.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	483	482	482	482	482
PH1 to N	483	482	482	483	483	483
PH2 to N	482	482	482	483	482	482
Amperage PH1	299	300	300	299	299	0
PH2	300	299	299	300	300	0
PH3	299	299	300	300	299	0
Kilowatts	250	250	250	250	250	0
Oil Pressure	58	55	53	53	53	55
Oil Temperature						
Coolant Temperature	185°F	189°F	191°F	191°F	191°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	87°F	87°F	87°F	87°F	88°F	88°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

## Charles Equipment

7-23-21

CSDG # 2991

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: Level Good -30F
- Yes  No  NA Visual inspection of radiator: No visible issues or performance issues
- Yes  No  NA Visual inspection of radiator hoses: No visible issues
- Yes  No  NA Check condition of coolant hoses: No visible issues
- Yes  No  NA Check condition of fuel hoses: No visible issues
- Yes  No  NA Check condition of engine belts: Good Condition
- Yes  No  NA Batteries and QTY: (2) 4D
- Yes  No  NA Battery install date if applicable: Not Dated
- Yes  No  NA Genset has battery charger: 120VAC/208-240 12/24 VDC NOM
- Yes  No  NA Genset has coolant heater: 120VAC/1500Watt Tank Heater
- Yes  No  NA Check engine oil level: Oil level is full
- Yes  No  NA Engine oil filters last changed date and HRS: 4-26-16 357.6Hrs.
- Yes  No  NA Inspect exhaust system for cracks / leaks: No issues with exhaust system
- Yes  No  NA Check rain cap for proper operation: OK
- Yes  No  NA Generator end is 12 lead reconnectable: OK
- Yes  No  NA Generator end has PMG permanent magnet generator: Yes