



Customer: Central States Diesel Generators STK#3059  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 12017  
 Test Date 10-5-21

Engine Make/ Model: Cummins QSL9-G2 NR3  
 Engine Spec/ Serial: 73054981  
 Unit Make/ Model: Cummins DSHAC-2168053  
 Unit Spec/ Serial: L090075986

Voltage: 277/480  
 Amperage: 241  
 Kilowatts: 200  
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	129.9	130.1	130.4	130.6	130.9	131
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	482	481	481	481
PH1 to N	482	482	482	482	482	482
PH2 to N	482	482	482	482	482	483
Amperage PH1	240	239	239	240	240	0
PH2	239	239	240	240	239	0
PH3	239	238	239	239	239	0
Kilowatts	200	200	200	200	200	0
Oil Pressure	62	60	59	59	59	62
Oil Temperature						
Coolant Temperature	187°F	187°F	188°F	187°F	187°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	69°F	69°F	70°F	70°F	70°F	71°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

## Charles Equipment

10-5-21

CSDG # 3059

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: **Level Good -35F**
- Yes  No  NA Visual inspection of radiator: **No visible issues or performance issues**
- Yes  No  NA Visual inspection of radiator hoses: **No visible issues**
- Yes  No  NA Check condition of coolant hoses: **No visible issues**
- Yes  No  NA Check condition of fuel hoses: **No visible issues**
- Yes  No  NA Check condition of engine belts: **Good Condition**
- Yes  No  NA Batteries and **QTY: (2) Group CSM24 / 12VDC**
- Yes  No  NA Battery install date if applicable: **2/21**
- Yes  No  NA Genset has battery charger: **NRG22-10-RC**
- Yes  No  NA Genset has coolant heater: **120V 1PH / 1500Watt**
- Yes  No  NA Check engine oil level: **OK**
- Yes  No  NA Engine oil filters last changed date and HRS: **12-14-20/98.6Hrs.**
- Yes  No  NA Inspect exhaust system for cracks / leaks: **No issues with exhaust system**
- Yes  No  NA Check rain cap for proper operation: **O.K.**
- Yes  No  NA Generator end is 12 lead reconnectable: **OK**
- Yes  No  NA Generator end has PMG permanent magnet generator: **NO**