



Customer: Central States Diesel Generators STK# 3119  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 12368  
 Test Date 12-13-21

Engine Make/ Model: DAEWOO DB33A  
 Engine Spec/ Serial: EBM0A200472  
 Unit Make/ Model: Generac 2652630100  
 Unit Spec/ Serial: SD0050-A163.3D18EPSYY

Voltage: 120/240 1PH  
 Amperage: 208  
 Kilowatts: 50  
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	508.2	508.5	508.7	509	509.2	509.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1 to PH2	242	243	243	243	242	242
PH1 to N	121	122	121	122	121	122
PH2 to N	122	121	121	121	122	123
Amperage PH1	207	207	207	207	207	0
PH2	206	207	207	207	206	0
PH3	0	0	0	0	0	0
Kilowatts	50	50	50	50	50	0
Oil Pressure	52	49	48	48	48	50
Oil Temperature						
Coolant Temperature	184°F	185°F	185°F	185°F	185°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	42°F	42°F	42°F	43°F	43°F	43°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

## Charles Equipment

12-13-21

CSDG # 3119

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: **Level Good -35F**
- Yes  No  NA Visual inspection of radiator: **Okay**
- Yes  No  NA Visual inspection of radiator hoses: **No visible issues**
- Yes  No  NA Check condition of coolant hoses: **Okay**
- Yes  No  NA Check condition of fuel hoses: **No visible issues**
- Yes  No  NA Check condition of engine belts: **Good Condition**
- Yes  No  NA Batteries and QTY: **Qty. 1 NAPA 7527 (NEEDS 2)**
- Yes  No  NA Battery install date if applicable:
- Yes  No  NA Genset has battery charge: **Generac 24VDC 2A output / 120VAC input**
- Yes  No  NA Genset has coolant heater: **QTY. (1) 120VAC/1000W Tank Type**
- Yes  No  NA Check engine oil level: **Oil level is full**
- Yes  No  NA Engine oil filters last changed date and HRS: **7/20 500Hrs.**
- Yes  No  NA Inspect exhaust system for cracks / leaks: **Okay**
- Yes  No  NA Check rain cap for proper operation: **Okay**
- Yes  No  NA Generator end is 12 lead reconnectable: **YES**
- Yes  No  NA Generator end has PMG permanent magnet generator: **NO**