



Customer: Central States Diesel Generators STK# 3157
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 12249
 Test Date 11-23-21

Engine Make/ Model: Detroit Diesel 6063HV
 Engine Spec/ Serial: -6R1010201
 Unit Make/ Model: Kohler 300REOZDD
 Unit Spec/ Serial: Spec GM41933-GA4 S/N 2216390

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	425	425.2	425.5	425.7	426	426.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1 to PH2	480	480	480	479	480	479
PH2 to PH3	481	481	480	480	481	481
PH1 to PH3	480	480	481	481	480	480
Amperage PH1	360	361	361	360	361	0
PH2	361	361	362	361	361	0
PH3	361	361	360	360	361	0
Kilowatts	300	300	300	300	300	0
Oil Pressure	52	51	51	50	50	52
Oil Temperature						
Coolant Temperature	183°F	184°F	184°F	184°F	184°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	28°F	28°F	28°F	29°F	29°F	30°F

Technician Signature: _____

Customer Signature: _____

Charles Equipment

11-23-21

CSDG # 3157

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: Level Good -30F
- Yes No NA Visual inspection of radiator: Okay
- Yes No NA Visual inspection of radiator hoses: No visible issues
- Yes No NA Check condition of coolant hoses: Okay
- Yes No NA Check condition of fuel hoses: No visible issues
- Yes No NA Check condition of engine belts: Good Condition
- Yes No NA Batteries and QTY: Qty.2 NAPA 7237
- Yes No NA Battery install date if applicable: 1/04
- Yes No NA Genset has battery charge: 120/240 INPUT/ 26VDC OUTPUT 10A
- Yes No NA Genset has coolant heater: QTY. (1) 208VAC 2500W
- Yes No NA Check engine oil level: Oil level is full
- Yes No NA Engine oil filters last changed date and HRS: Not Dated
- Yes No NA Inspect exhaust system for cracks / leaks: Okay
- Yes No NA Check rain cap for proper operation: Okay
- Yes No NA Generator end is 12 lead reconnectable: YES
- Yes No NA Generator end has PMG permanent magnet generator: NO