

GENERAC

Customer: CSDG
 Address: _____
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 12181
 Test Date 11/17/2021

Engine Make/ Model: Caterpillar C15
 Engine Spec/ Serial: FTE02639
 Unit Make/ Model: Caterpillar 500
 Unit Spec/ Serial: G6B22969

Voltage: 480VAC
 Amperage: 751A
 Kilowatts: 500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	701	701	701	701	702							702
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	300	603	603	604	604							0
PH2	301	602	602	602	603							0
PH3	299	601	602	602	601							0
Kilowatts	249	500	500	500	500	0	0	0	0	0	0	0
Oil Pressure	77	62	59	59	56							58
Oil Temperature												
Coolant Temperature	171°F	192°F	192°F	192°F	192°F							182°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature	505°F	701°F	892°F	945°F	945°F							421°F
DC Voltage	27	27	27	27	27							27
Natural Gas Pressure												
Diesel Fuel Level	100	100	100	100	100							100
Room Temperature												
Ambient Temperature	63°F	62°F	62°F	62°F	61°F							61°F

Cable Length: 25Cable/ Leg: 2Connection Point: Output breakerTechnician Signature: John Colini

Customer Signature: _____