

**GENERAC**

Customer: Central States Diesel Generators STK#3244  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: \_\_\_\_\_

R#: 12741  
 Test Date 2/3/2022

Engine Make/ Model: CUMMINS 6CTAA8.3G1  
 Engine Spec/ Serial: 45792240  
 Unit Make/ Model: CUMMINS/ONAN 200DGFC-41869B  
 Unit Spec/ Serial: L980843156. 01

Voltage: 480  
 Amperage: 240  
 Kilowatts: 200  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	285.3	285.6	285.8	286	286.3							286.6
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	482	482	482	482	482							480
PH2	482	482	482	482	482							480
PH3	482	482	482	482	482							480
Amperage PH1	122	122	240	240	240							0
PH2	122	122	240	240	240							0
PH3	122	122	240	240	240							0
Kilowatts	102	102	200	200	200	0	0	0	0	0	0	0
Oil Pressure	65	60	55	55	55							60
Oil Temperature												
Coolant Temperature	175°F	180°F	185°F	185°F	185°F							170°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	14.57	14.57	14.57	14.57	14.57							14.57
Natural Gas Pressure												
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	19°F	19°F	19°F	19°F	19°F							19°F

Cable Length: 15Cable/ Leg: 1Connection Point: GENERATOR BREAKERTechnician Signature: Rudy Aceves

Customer Signature: \_\_\_\_\_