



Customer: Central States Diesel Generators STK# 3509  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 12752  
 Test Date 2-10-22

Engine Make/ Model: John Deere 6068HF285  
 Engine Spec/ Serial: PE6068N014720  
 Unit Make/ Model: Kohler 150REOZJF  
 Unit Spec/ Serial: Spec. GM81645-GA1 S/N- 3379GMHJ0028

Voltage: 120/240  
 Amperage: 361  
 Kilowatts: 150  
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	4561.2	4561.4	4561.7	4561.9	4562.1	4562.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1 to PH2	237	236	236	237	237	237
PH2 to PH3	241	241	242	242	241	241
PH1 to PH3	242	242	241	242	241	242
Amperage PH1	360	361	361	360	361	0
PH2	361	361	360	360	361	0
PH3	360	361	361	361	362	0
Kilowatts	150	150	150	150	150	0
Oil Pressure	56	55	55	55	55	57
Oil Temperature						
Coolant Temperature	182°F	182°F	183°F	183°F	183°F	181°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	23°F	23°F	23°F	24°F	24°F	24°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

## Charles Equipment

2-10-22

CSDG # 3509

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: Level Good Freeze @ -35 Deg. F
- Yes  No  NA Visual inspection of radiator: No visible issues
- Yes  No  NA Visual inspection of radiator hoses: No visible issues
- Yes  No  NA Check condition of coolant hoses: No visible issues
- Yes  No  NA Check condition of fuel hoses: No visible issues
- Yes  No  NA Check condition of engine belts: No Visible issues
- Yes  No  NA Batteries and QTY: Not Present
- Yes  No  NA Battery install date if applicable: N/A
- Yes  No  NA Genset has battery charger: Kohler GM87448 100-240VAC 12/24V 10A
- Yes  No  NA Genset has coolant heater: QTY. (1) 120VAC 1800 Watt
- Yes  No  NA Check engine oil level: Oil level is full
- Yes  No  NA Engine oil filters last changed date and HRS: 12-19-21 4558Hrs.
- Yes  No  NA Inspect exhaust system for cracks / leaks: No visible issues
- Yes  No  NA Check rain cap for proper operation: Okay
- Yes  No  NA Generator end is 12 lead reconnectable: Yes
- Yes  No  NA Generator end has PMG permanent magnet generator: YES