



Customer: Central States Diesel Generators STK# 3519  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 12817  
 Test Date 2-21-22

Engine Make/ Model: Ford WSG1068I6005E-TC  
 Engine Spec/ Serial: 03-02-051564  
 Unit Make/ Model: Olympian G100F3  
 Unit Spec/ Serial: OLY00000TNFC00883

Voltage: 120/208  
 Amperage: 278  
 Kilowatts: 100 (Test@72/LP)  
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	198.9	199.1	199.4	199.6	199.9	200
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1 to PH2	209	210	210	209	209	209
PH2 to PH3	210	210	209	209	209	210
PH1 to PH3	209	209	209	210	209	209
Amperage PH1	199	198	198	198	199	0
PH2	197	198	198	199	198	0
PH3	198	198	197	198	198	0
Kilowatts	72	72	72	72	72	0
Oil Pressure	61	60	60	60	60	63
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.5	14.5	14.5	14.5	14.5	14.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	30°F	30°F	30°F	30°F	30°F	30°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

## Charles Equipment

2-21-22

CSDG # 3519

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: Level Good Freeze @ -30 Deg. F
- Yes  No  NA Visual inspection of radiator: No visible issues
- Yes  No  NA Visual inspection of radiator hoses: No visible issues
- Yes  No  NA Check condition of coolant hoses: No visible issues
- Yes  No  NA Check condition of fuel hoses: No visible issues
- Yes  No  NA Check condition of engine belts: No Visible issues
- Yes  No  NA Batteries and QTY: Qty. (1) Duralast 65S-DLG
- Yes  No  NA Battery install date if applicable: Not Marked
- Yes  No  NA Genset has battery charger: SENS LC12-500-2 120VAC/8A
- Yes  No  NA Genset has coolant heater: 120VAC/1500W Tank Type
- Yes  No  NA Check engine oil level: Oil level is full
- Yes  No  NA Engine oil filters last changed date and HRS: 1-15-20 197Hrs.
- Yes  No  NA Inspect exhaust system for cracks / leaks: No visible issues
- Yes  No  NA Check rain cap for proper operation: Okay
- Yes  No  NA Generator end is 12 lead reconnectable: YES
- Yes  No  NA Generator end has PMG permanent magnet generator: YES