



Customer: Central States Diesel Generators
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip: Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 21622-1
 Test Date: 3/3/2022

CSDG Unit # 3 5 2 5

Engine Make/ Model: Detroit Series 60
 Engine Spec/ Serial: 0 6 R 0 8 5 0 9 3 7
 Unit Make/ Model: Kohler 250RZDB
 Unit Spec/ Serial: 2 0 8 4 8 1 6

Voltage: 480
 Amperage: 375 @.8 PF / 301 @ 1.0 PF
 Kilowatts: 250
 Power Factor: 0.8

	5 Min.	15 Min.	20 Min.	25 Min.	30 Min	45 Min.	1 Hour	Cool down
Eng Hours	681.8	682	682.1	682.2	682.3	682.5	682.7	682.8
Hertz/Cycles	60	60	60	60	60	60	60	60.5
AC Voltage PH1	480	480	480	480	480	480	480	480
PH2	480	480	480	480	480	480	480	480
PH3	480	480	480	480	480	480	480	480
Amperage PH1	60	120	300	300	300	300	300	0
PH2	60	120	300	300	300	300	300	0
PH3	60	120	300	300	300	300	300	0
Kilowatts	50	100	250	250	250	250	250	0
Oil Pressure	80	80	75	75	72	72	72	72
Oil Temperature	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Coolant Temperature	165°F	175°F	180°F	180°F	180°F	180°F	180°F	175°F
Exhaust Temperature	1000°F	1050°F	1075°F	1100°F	1100°F	1125°F	1150°F	1000°F
DC Voltage	26	26	27	27	27	27	27	27
Natural Gas Pressure	11"	11"	11"	11"	11"	11"	11"	11"
Ambient Temperature	36°F	36°F	36°F	36°F	36°F	36°F	36°F	36°F

Technician Signature: Michael R. Biehl Sr.

Customer Signature: _____