



Customer: Central States Diesel Generators STK#3536
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 12966
 Test Date 4-15-22

Engine Make/ Model: Cummins 6CTA8.3
 Engine Spec/ Serial: 21263564
 Unit Make/ Model: Cummins 200DGFC
 Unit Spec/ Serial: Spec.- 89357A S/N - I970648511

Voltage: 277/480
 Amperage: 241
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1103.1	1103.4	1103.6	1103.9	1104.1	1104.2
Hertz/Cycles	60	60.1	60	60	60.1	60
Voltage PH1	482	482	481	482	481	482
PH2	481	481	480	481	481	481
PH3	481	481	481	480	481	480
Amperage PH1	240	240	239	239	240	0
PH2	239	239	240	240	240	0
PH3	240	240	239	239	240	0
Kilowatts	200	200	199	199	200	0
Oil Pressure	57	56	55	55	55	58
Oil Temperature						
Coolant Temperature	180°F	181°F	181°F	181°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.4	13.4	13.4	13.4	13.4	13.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	32°F	32°F	32°F	32°F	33°F	33°F

Technician Signature: _____

Customer Signature: _____

Charles Equipment

4-18-22

CSDG # 3536

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: Level Good Freeze @ -35 Deg. F
- Yes No NA Visual inspection of radiator: No visible issues
- Yes No NA Visual inspection of radiator hoses: No visible issues
- Yes No NA Check condition of coolant hoses: No visible issues
- Yes No NA Check condition of fuel hoses: No visible issues
- Yes No NA Check condition of engine belts: No Visible issues (New 4-18-22)
- Yes No NA Batteries and QTY: Qty (1) KOHLER GM106376-S 4D
- Yes No NA Battery install date if applicable: 9/3/2020
- Yes No NA Genset has battery charger: C-CHARGER 120VAC input 12VDC/10A output
- Yes No NA Genset has coolant heater: Kim Hotstart TPS151GT10-000 120VAC/1500W
- Yes No NA Check engine oil level: Oil level is full
- Yes No NA Engine oil filters last changed date and HRS: 9-6-21 1099.4 Hrs.
- Yes No NA Inspect exhaust system for cracks / leaks: No visible issues
- Yes No NA Check rain cap for proper operation: Okay
- Yes No NA Generator end is 12 lead reconnectable: YES
- Yes No NA Generator end has PMG permanent magnet generator: YES