



Customer: Central States Diesel Generators STK#3554
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 13081
 Test Date 4-6-22

Engine Make/ Model: Mitsubishi QT45 4G64S4M
 Engine Spec/ Serial: SGX5791
 Unit Make/ Model: Generac QTO4524GNSN
 Unit Spec/ Serial: 5620051

Voltage: 120/208
 Amperage: 125
 Kilowatts: 45
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	79.8	80	80.3	80.5	80.8	80.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	207	207	208	207	207	207
PH2	208	208	207	207	208	208
PH3	207	207	207	206	207	207
Amperage PH1	124	124	125	125	125	0
PH2	125	125	125	124	124	0
PH3	124	124	125	125	125	0
Kilowatts	45	45	45	45	45	0
Oil Pressure	OK	OK	OK	OK	OK	OK
Oil Temperature						
Coolant Temperature	OK	OK	OK	OK	OK	OK
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.5	13.5	13.5	13.5	13.5	13.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	38°F	38°F	38°F	38°F	37°F	37°F

Technician Signature: _____

Customer Signature: _____

Charles Equipment

4-7-22

CSDG # 3554

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: Level Good Freeze @ -35 Deg. F
- Yes No NA Visual inspection of radiator: No visible issues
- Yes No NA Visual inspection of radiator hoses: No visible issues
- Yes No NA Check condition of coolant hoses: No visible issues
- Yes No NA Check condition of fuel hoses: No visible issues
- Yes No NA Check condition of engine belts: No Visible issues
- Yes No NA Batteries and QTY: Qty. Not Present
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level: Oil level is full
- Yes No NA Engine oil filters last changed date and HRS: Not Marked
- Yes No NA Inspect exhaust system for cracks / leaks: No visible issues
- Yes No NA Check rain cap for proper operation: Okay