



Load Bank Test Report

Engine Make/ Model: John Deere 6068HF475
Engine Spec/ Serial: John Deere PE6068L114688
Unit Make/ Model: Baldor TS250T
Unit Spec/ Serial: P1110270012

Voltage: Multiple
Amperage: Multiple
Kilowatts: 200
Power Factor: 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	14093.1	14093.2	14093.4	14093.7	14093.9	14094.2	14094.3
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	482	484	485	485	485	485	485
PH2	482	484	485	485	485	485	485
PH3	481	493	485	485	485	485	485
Amperage PH1	0	232	232	232	232	232	0
PH2	0	232	232	232	232	232	0
PH3	0	232	232	232	232	232	0
Kilowatts	0	196	196	196	196	196	0
Oil Pressure	64	46	44	43	43	43	53
Coolant Temperature	152	183°F	199°F	206°F	206°F	206°F	168°F
DC Voltage	14.6	14.6	14.6	14.6	14.6	14.6	14.6
Ambient Temperature	55	55°F	55°F	55°F	55°F	55°F	55°F

Technician Signature Jack Standley Jr

Test Date 5/24/2022



5/24/2022

CSDG #3591

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -35F, Water pump, thermostats replaced. New coolant added.
- Yes No NA Visual inspection of radiator: Clean, no leaks
- Yes No NA Visual inspection of radiator hoses: Good, no leaks
- Yes No NA Check condition of coolant hoses: Good, no leaks
- Yes No NA Check condition of fuel hoses: Good, no leaks
- Yes No NA Check condition of engine belts: Replaced, 05/12/2022
- Yes No NA Batteries and QTY: Group 31 QTY 1
- Yes No NA Battery install date if applicable: 05/12/2022
- Yes No NA Genset has battery charger: No battery charger
- Yes No NA Genset has coolant heater: 120V, 1500W QTY 1
- Yes No NA Check engine oil level: Good, changed
- Yes No NA Engine oil filters last changed date and HRS: 05/12/2022, 14093
- Yes No NA Inspect exhaust system for cracks / leaks: No leaks
- Yes No NA Check rain cap for proper operation: Turn down exhaust
- Yes No NA Generator end is 12 lead reconnectable: Mobile unit, multiple voltage
- Yes No NA Generator end has PMG permanent magnet generator: Yes