



Customer: Central States Diesel Generators STK#3822
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 14582
 Test Date 1-31-24

Engine Make/ Model: CATERPILLAR 3412
 Engine Spec/ Serial: 81Z23744
 Unit Make/ Model: CATERPILLAR 3412
 Unit Spec/ Serial: 81Z23744

Voltage: 277/480
 Amperage: 601
 Kilowatts: 500
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1262	1262	1262	1262	1262	1263
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	477	477	477	478	477	478
PH1-PH3	475	475	476	476	475	475
PH2-PH3	480	480	481	481	480	480
Amperage PH1	618	618	617	618	618	0
PH2	619	619	619	620	619	0
PH3	571	572	571	571	572	0
KILOWATTS	500	500	500	500	500	0
Oil Pressure	67	67	67	66	66	68
Oil Temperature						
Coolant Temperature	180°F	180°F	181°F	181°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	32°F	32°F	32°F	33°F	33°F	33°F

Technician Signature: _____

Customer Signature: _____