



Customer: Central States Diesel Generators STK#3841
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 14696
 Test Date 10-20-23

Engine Make/ Model: GM 8.1L
 Engine Spec/ Serial: 8.1L12658
 Unit Make/ Model: KOHLER 125ROZG
 Unit Spec/ Serial: Spec. GM34464-GA1 S/N 2098689

Voltage: 120/208
 Amperage: 361
 Kilowatts: 130 (TEST@80KW LP)
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1024	1024.2	1024.5	1024.7	1025	1025.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	210	210	210	210	211	210
PH2-PH3	210	211	211	211	210	210
PH1-PH3	210	209	209	210	210	210
Amperage PH1	220	221	221	220	220	0
PH2	219	219	220	220	220	0
PH3	221	221	220	220	220	0
KILOWATTS	80	80	80	80	80	0
Oil Pressure	50	49	48	48	48	52
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	50°F	50°F	51°F	51°F	51°F	52°F

Technician Signature: _____

Customer Signature: _____



10/20/2023

CSDG #3841

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -30F
- Yes No NA Visual inspection of radiator: Good
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: (1) 24-XD
- Yes No NA Battery install date if applicable: Not Marked
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater: 120V/1500W Tank Type
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: Not Marked
- Yes No NA Inspect exhaust system for cracks / leaks: None
- Yes No NA Check rain cap for proper operation: O.K.
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: PSI
- Yes No NA Mechanical Engine: