



Load Bank Test Report

Engine Make/ Model: Detroit 60 Series
Engine Spec/ Serial: Detroit 06R0667435
Unit Make/ Model: Spectrum 350DSE
Unit Spec/ Serial: 718627

Voltage: 208
Amperage: 1000
Kilowatts: 360
Power Factor: 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	231.7	231.8	232	232.3	232.6	232.8	232.9
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208	208
PH2	208	208	208	208	208	208	208
PH3	208	208	208	208	208	208	208
Amperage PH1	0	1001	1001	1001	1001	1001	0
PH2	0	1001	1001	1001	1001	1001	0
PH3	0	1001	1001	1001	1001	1001	0
Kilowatts	0	360	360	360	360	360	0
Oil Pressure	60	55	53	53	52	51	55
Coolant Temperature	154	185°F	185°F	186°F	186°F	186°F	179°F
DC Voltage	27.5	27.5	27.6	27.6	27.5	27.6	27.5
Ambient Temperature	35	35°F	35°F	35°F	35°F	35°F	35°F

Technician Signature Jack Standley Jr

Test Date 1/9/2023



01/09/2023

CSDG #3851

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -22F
- Yes No NA Visual inspection of radiator: Clean, no leaks
- Yes No NA Visual inspection of radiator hoses: Good
- Yes No NA Check condition of coolant hoses: Good
- Yes No NA Check condition of fuel hoses: Good
- Yes No NA Check condition of engine belts: Good
- Yes No NA Batteries and QTY: No batteries
- Yes No NA Battery install date if applicable: NA
- Yes No NA Genset has battery charger: Yes
- Yes No NA Genset has coolant heater: 120V, 2500W
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 2/1/2020 200Hrs
- Yes No NA Inspect exhaust system for cracks / leaks: Open exhaust
- Yes No NA Check rain cap for proper operation: No rain cap
- Yes No NA Generator end is 12 lead reconnectable: Yes
- Yes No NA Generator end has PMG permanent magnet generator: Yes
- Yes No NA Electronic Engine: Yes
- Yes No NA Mechanical Engine: No