



**02/01/2024**

**CSDG #3854**

### **Generator Check list**

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: -25F
- Yes  No  NA Visual inspection of radiator: Excellent
- Yes  No  NA Visual inspection of radiator hoses: Good
- Yes  No  NA Check condition of coolant hoses: Good
- Yes  No  NA Check condition of fuel hoses: Good
- Yes  No  NA Check condition of engine belts: Good
- Yes  No  NA Batteries and QTY: 1 (NAPA 7524)
- Yes  No  NA Battery install date if applicable: 08/2022
- Yes  No  NA Genset has battery charger:
- Yes  No  NA Genset has coolant heater: 1000W 120V
- Yes  No  NA Check engine oil level: Full
- Yes  No  NA Engine oil filters last changed date and HRS: 02/02/2024
- Yes  No  NA Inspect exhaust system for cracks / leaks: Good
- Yes  No  NA Check rain cap for proper operation: Good
- Yes  No  NA Generator end is 12 lead reconnectable: Yes
- Yes  No  NA Generator end has PMG permanent magnet generator:
- Yes  No  NA Mechanical Engine: