



Customer: Central States Diesel Generators STK#3922  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 14701  
 Test Date 5-5-23

Engine Make/ Model: FORD WSG1068I6005E-TC  
 Engine Spec/ Serial: 03-12-068908  
 Unit Make/ Model: OLYMPIAN G100F3  
 Unit Spec/ Serial: OLY00000CNFC01501

Voltage: 277/480  
 Amperage: 120  
 Kilowatts: 100  
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	874.8	875	875.3	875.5	875.8	875.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1-PH2	487	487	486	487	486	487
Voltage PH1-PH3	486	486	487	487	486	486
Voltage PH2-PH3	487	488	487	487	487	487
Amperage PH1	118	119	118	118	118	0
PH2	118	119	119	118	118	0
PH3	119	118	118	118	118	0
KILOWATTS	99	99	99	99	99	0
Oil Pressure	65	64	64	62	62	64
Oil Temperature						
Coolant Temperature	200°F	200°F	201°F	201°F	201°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	73°F	73°F	73°F	72°F	72°F	72°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

## Charles Equipment

5-5-23

CSDG # 3922

### Generator Check list

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: Level Good -30F
- Yes  No  NA Visual inspection of radiator: No visible issues or performance issues
- Yes  No  NA Visual inspection of radiator hoses: No visible issues
- Yes  No  NA Check condition of coolant hoses: Good Condition
- Yes  No  NA Check condition of fuel hoses: No visible issues
- Yes  No  NA Check condition of engine belts: Good Condition
- Yes  No  NA Batteries and QTY: (1) NAPA 7234
- Yes  No  NA Battery install date if applicable: NOT MARKED
- Yes  No  NA Genset has battery charger: NO
- Yes  No  NA Genset has coolant heater: 120VAC 1500W Tank Type
- Yes  No  NA Check engine oil level: Oil level is full
- Yes  No  NA Engine oil filters last changed date and HRS: Not Marked
- Yes  No  NA Inspect exhaust system for cracks / leaks: No issues with exhaust system
- Yes  No  NA Check rain cap for proper operation: Good
- Yes  No  NA Generator end is 12 lead reconnectable: YES
- Yes  No  NA Generator end has PMG permanent magnet generator: AREP